

階	系統	室名	吹出口	総風量 (m3/h)	形式	サイズ		風量 (m3/h)	個数	ボックス		内径 φ25	備考	吸込口	総風量 (m3/h)	形式	サイズ		風量 (m3/h)	個数	ボックス		内径 φ25	備考		
						2.5 x 75%	開口率			W x L x H	2.5 x 75%						開口率	W x L x H								
5	GHP-11-1×2	取引振興課	SA	2,520	E2	#25	420	6	450 × 450 × 400	○				RA	2,520	HS	300 × 300	420	6	500 × 500 × 400	○					
	GHP-11-2	取引振興課	SA	840	E2	#25	420	2	450 × 450 × 400	○				RA	840	HS	300 × 300	420	2	500 × 500 × 400	○					
	GHP-11-2	打合せ室1	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○					
	GHP-11-2	取引振興課	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○					
	GHP-11-2	打合せ室2	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○					
	GHP-11-2	打合せ室3	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○					
	GHP-11-2	取引振興課	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	2	500 × 500 × 400	○					
	GHP-11-2	取引振興課	SA	420	E2	#25	420	2	450 × 450 × 400	○																
	GHP-11-2	ロッカー室1	SA	210	VHS	200 × 200	210	1	400 × 400 × 400	○				RA	210	HS	200 × 200	210	1	450 × 450 × 400	○					
	GHP-11-2	ロッカー室2	SA	210	VHS	200 × 200	210	1	400 × 400 × 400	○				RA	210	HS	200 × 200	210	1	450 × 450 × 400	○					
		取引振興課	SA	190	VHS	150 × 150	190	1	350 × 350 × 350	○	(取引振興課)			0A'n's	190	HS	150 × 150	190	1	350 × 350 × 350	○	(ロッカー室1)				
		取引振興課	0A'n's	190	VHS	150 × 150	190	1	350 × 350 × 350	○	(取引振興課)			0A'n's	190	HS	150 × 150	190	1	350 × 350 × 350	○	(ロッカー室2)				
		取引振興課	0A'n's	190	VHS	150 × 150	190	1	350 × 350 × 350	○	(取引振興課)															
	HEX-5-1	取引振興課	0A	880	(RAチャンバー)	440	2				GHP-11-1,2			EA	750	HS	250 × 250	375	2	450 × 450 × 400						
	HEX-5-1	打合せ室1												EA	130	HS	150 × 150	130	1	350 × 350 × 350						
	HEX-5-2	取引振興課	0A	240	(RAチャンバー)	240	1				GHP-11-1			EA	360	HS	200 × 200	180	2	400 × 400 × 350						
	HEX-5-2	取引振興課	0A	390	(RAチャンバー)	390	1				GHP-11-2															
	HEX-5-2	取引振興課	0A	110	(RAチャンバー)	110	1				GHP-11-2															
	HEX-5-2	相談室 9-1	0A	130	VHS	150 × 150	130	1	350 × 350 × 350	○																
	HEX-5-2	相談室 9-2	0A	130	VHS	150 × 150	130	1	350 × 350 × 350	○																
HEX-5-2	打合せ室2												EA	130	HS	150 × 150	130	1	350 × 350 × 350							
HEX-5-2	打合せ室3												EA	130	HS	150 × 150	130	1	350 × 350 × 350							
HEX-5-2	ロッカー室1												EA	190	HS	200 × 200	190	1	400 × 400 × 350							
HEX-5-2	ロッカー室2												EA	190	HS	200 × 200	190	1	400 × 400 × 350							
	取引振興課	EA'n's	130	VHS	150 × 150	130	2	350 × 350 × 350	○	(相談室 9-1・2)																
	相談室 9-1												EA'n's	130	HS	150 × 150	130	1	350 × 350 × 350	○	(取引振興課)					
	相談室 9-2												EA'n's	130	HS	150 × 150	130	1	350 × 350 × 350	○	(取引振興課)					
	取引振興課												0A'n's	390	HS	150 × 150	130	3	350 × 350 × 350	○	(打合せ室1・2・3)					
	打合せ室1	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○																	
	打合せ室2	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○																	
	打合せ室3	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○																	
GHP-12-1×3	総合支援課	SA	3,780	E2	#25	420	9	450 × 450 × 400	○				RA	3,780	HS	300 × 300	420	9	500 × 500 × 400	○						
GHP-12-3	総合支援課	SA	1,560	E2	#25	390	4	450 × 450 × 400	○				RA	1,560	HS	250 × 250	390	4	450 × 450 × 400	○						
GHP-12-2	総合支援課	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○						
GHP-12-2	ロッカー室 3, 4	SA	840	E2	#25	420	2	450 × 450 × 400	○				RA	840	HS	300 × 300	420	2	500 × 500 × 400	○						
GHP-12-2	総合支援課	SA	840	E2	#25	420	2	450 × 450 × 400	○				RA	840	HS	300 × 300	420	2	500 × 500 × 400	○						
GHP-12-2	相談室 6	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○						
GHP-12-2	総合支援課	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○						
GHP-12-2	相談室 7	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○						
GHP-12-2	相談室 8	SA	420	E2	#25	420	1	450 × 450 × 400	○				RA	420	HS	300 × 300	420	1	500 × 500 × 400	○						
HEX-5-3	総合支援課	0A	390	(RAチャンバー)	390	1				GHP-12-2			EA	390	HS	200 × 200	195	2	400 × 400 × 400							
HEX-5-3	総合支援課	0A	510	(RAチャンバー)	255	2				GHP-12-1,2																
HEX-5-3	ロッカー室 3, 4												EA	380	HS	200 × 200	190	2	400 × 400 × 400							
HEX-5-3	相談室 6												EA	130	HS	150 × 150	130	2	350 × 350 × 350							
	総合支援課	0A'n's	380	HS	200 × 200	190	2	400 × 400 × 400	○	(総合支援課)			0A'n's	380	HS	200 × 200	190	2	400 × 400 × 400	○	(ロッカー室 3・4)					
HEX-5-4	総合支援課	0A	600	(RAチャンバー)	300	2				GHP-12-1×2			EA	730	HS	250 × 250	365	2	450 × 450 × 400							
HEX-5-4	総合支援課	0A	390	(RAチャンバー)	390	1				GHP-12-2																
HEX-5-4	相談室 7, 8												EA	260	HS	150 × 150	130	2	350 × 350 × 350							
HEX-5-5	総合支援課	0A	320	(RAチャンバー)	320	1				GHP-12-3			EA	970	HS	300 × 300	485	2	500 × 500 × 450							
HEX-5-5	相談室 1～5	0A	650	VHS	150 × 150	130	5	350 × 350 × 350	○																	
	総合支援課	EA'n's	650	VHS	150 × 150	130	5	350 × 350 × 350	○				EA'n's	650	HS	150 × 150	130	5	350 × 350 × 350	○	(相談室 1～5)					
	相談室 6	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○	(総合支援課)			0A'n's	390	HS	150 × 150	130	3	350 × 350 × 350	○	(相談室 6～8)					
	相談室 7	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○	(総合支援課)																
	相談室 8	0A'n's	130	VHS	150 × 150	130	1	350 × 350 × 350	○	(総合支援課)																
EXF-R-2	湯沸室												EA	200	HS	200 × 200	200	1	450 × 450 × 350							
EXF-R-1	男子便所												EA	340	HS	150 × 150	85	4	350 × 350 × 350							
EXF-R-1	女子便所												EA	340	HS	150 × 150	114	3	350 × 350 × 350							
GHP-21-1	廊下	SOA	680	VHS	350 × 350	680	1	550 × 550 × 400	○																	
EXF-5-1	屋外	EA	30	VC	100φ	30	1																			

階	系統	室名	吹出口	
---	----	----	-----	--