

階	系統	室名	吹出口	総風量 (m3/h)	形式	サイズ (m/s(面速) (開口率))	風量 (m3/h)	個数	ボックス W x L x H	内径 Ø25	備考	吸込口	総風量 (m3/h)	形式	サイズ (m/s(面速) (開口率))	風量 (m3/h)	個数	ボックス W x L x H	内径 Ø25	備考			
B2	0AF-B2-1, EXF-B1-10	発電機室	OA	14,700	VHS	1500 × 900	14,700	1				EA	29,400	HS	1600 × 800	14,700	2			通常時給気量 1,960m3			
	0AF-B2-1, EXF-B1-10	発電機室	OA	14,700	VHS	750 × 900	7,350	2															
	0AF-B2-1, EXF-B1-10	電気室	OA	5,850	VHS	1500 × 500	2,925	2				EA	5,850	HS	1800 × 600	2,925	2						
	0AF-B2-1, EXF-B1-10	ポンプ室 (実験排水用)										EA	390	HS	400 × 200	390	1						
	0AF-B2-1, EXF-B1-10	衛生機械室										EA	1,780	HS	1000 × 300	1,780	1						
	0AF-B2-1, EXF-B1-10	ハロンポンプ室	OA	420	VHS	300 × 200	420	1				EA	420	HS	400 × 200	420	1						
	0AF-B2-1, EXF-B1-10	ガスメーター室	OA	400	VHS	300 × 200	400	1				EA	400	HS	200 × 250	400	1						
	0AF-B2-1, EXF-B1-10	倉庫	OA	2,000	VHS	500 × 300	1,000	2				EA	2,000	HS	1200 × 600	1,000	2						
	0AF-B2-1, EXF-B1-10	廊下	OA	2,170	VHS	550 × 300	1,085	2															
	EXF-B1-1	機械駐車場										EA	2,100	HS	400 × 500	1,050	2						
	EXF-B2-1	廊下	EA	100	VC	100φ	100	1													FD付		
B1	EHP-4-1	会議室	SA	4,800	VHS	600 × 600	2,400	2	700 × 400 × 700			RA	3,750	HS	700 × 1000	3,750	1	900 × 400 × 1200			フィルター付		
	EXF-B1-2	会議室										EA	1,050	HS	450 × 450	1,050	1	550 × 550 × 500					
	EHP-2-1	電話交換機室	SA	690	VHS	250 × 250	345	2	450 × 450 × 400			RA	690		機器吸込	690	1						
	0AF-B2-2	電話交換機室	SA	70	金網	100φ		1															
	0AF-B2-2	廊下	OA	230	VHS	200 × 200	230	1	400 × 400 × 300														
	0AF-B2-2	倉庫1	OA	960	VHS	300 × 600	960	1															
	EXF-B1-3	倉庫2										EA	960	金網	400φ	960	1						
	0AF-B1-2	サーバーメンテナンス室	OA	100	VHS	150 × 150	100	1	350 × 350 × 350														
	EXF-B1-4	サーバーメンテナンス室										EA	100	VHS	150 × 150	100	1	350 × 350 × 350					
	EXF-B1-5	シャワー室										EA	100	RG	100φ	50	1						
		脱衣室										EA	100	HS	150 × 150	50	1	350 × 350 × 350					
	EXF-B1-6	便所										EA	200	HS	200 × 200	200	1	400 × 400 × 350					
	EXF-B1-7	受付控室										EA	70	HS	150 × 150	70	1	350 × 350 × 350					
		湯沸室										EA	140	HS	150 × 150	140	1	350 × 350 × 350					
	EHP-3-1	仮眠室	SA	440	VHS	300 × 300	440	1	500 × 500 × 400														
	EHP-3-1	警備員室	SA	820	VHS	400 × 400	820	1	600 × 600 × 400			RA	1,260		機器吸込	1,260	1						
		警備員室										バス	70	HS	150 × 150	70	1	350 × 350 × 350					
		廊下	バス	70	VHS	150 × 150	70	1	350 × 350 × 350														
	EXF-B1-8	車路	EA	70	VC	150φ	70	1													FD付		
	EXF-B1-1	車路										EA	2,900	HS	700 × 400	1,450	2						
	EXF-B1-9	ゴミ置場										EA	440	HS	300 × 300	440	1						
	0AF-B1-1	機械駐車場	OA	2,100	VHS	500 × 300	1,050	2															
1	GHP-3-1	持ち合わせスペース	SOA	770	VHS	250 × 250	385	2	450 × 450 × 400														
	0AF-1-1	設備スペース1	OA	320		(RAチャンバー)	320	1															
	GHP-1-1	玄関ホール・受付	SA	1,840	バス	#8	460	4													無結露タイプ		
	GHP-1-1	玄関ホール・受付	SA	2,420	E2	#25	605	4	450 × 450 × 450													無結露タイプ	
	GHP-1-1	ELVホール	SA	540	BL-T	1,000L	270	2	300 × 1200 × 400													無結露タイプ	
	GHP-1-1	設備スペース1	RA ⁿ ス	4,480	金網	800 × 250	4,480	1				RA	4,480	HS	700 × 1000	4,480	1	(RAチャンバー)				設計外気量 320m3	
	GHP-1-1	持ち合わせスペース										RA ⁿ ス	4,480	HS	1000 × 700	4,480	1	1200 × 900 × 300					
	GHP-2-2×2	大会議室	SA	5,280	角バス	500 × 250	1320	4				RA	5,280	HS	300 × 1700	2,640	2	500 × 600 × 1900				オート温度センサー付	
	HEX-1-1	大会議室	OA	1,360	バス	#12	453	3				EA ⁿ ス	1,360	HS	700 × 300	1,360	1	900 × 500 × 500					
	HEX-1-1	通路	EA ⁿ ス	1,360	VHS	700 × 300	1,360	1	900 × 500 × 500			EA ⁿ ス	1,360	HS	700 × 300	1,360	1	900 × 500 × 500					
	HEX-1-1	設備スペース3	EA	1,360																		HEX-1-1 RAIに接続	
	HEX-1-2	小会議室	OA	930	E2	#20	310	3	400 × 400 × 400			EA	930	HS	250 × 250	310	3	450 × 450 × 400					
	EXF-1-1	女子便所										EA	360	HS	150 × 150	60	6	350 × 350 × 350					
	EXF-1-2	男子便所										EA	350	HS	150 × 150	117	3	350 × 350 × 350					
	EXF-1-3	湯沸室										EA	200	HS	200 × 200	200	1	400 × 400 × 350					
	EXF-1-3	屋外	EA	200	VC	200φ	200	1															
2	0AF-2-1	大会議室 吹抜	OA	480	バス	#12	480	1															
	0AF-2-1	設備スペース4										OA	480	金網	250φ	480	1						
	EXF-2-1	大会議室 吹抜										EA	220	HS	200 × 200	220	1						
	EXF-2-2	玄関ホール・受付吹抜										EA	220	金網	200φ	220	1						
	EXF-2-2、EXF-2-3	屋外	EA	550	VC	250φ	550	1															
	EXF-2-3	女子便所										EA	330	HS	150 × 150	110	3	350 × 350 × 350					
	EXF-2-4	湯沸室										EA	200	HS	200 × 200	200	1	400 × 400 × 350					
	EXF-2-6	男子便所										EA	350	HS	150 × 150	117	3	350 × 350 × 350					
	EXF-2-7	倉庫										EA	160	金網	200φ	160	1						
	GHP-4-1	企業人材支援課	SA	3,840	E2	#25	480	8	450 × 450 × 400														
	GHP-4-2	企業人材支援課	SA	1,920	E2	#25	480	4	450 × 450 × 400														
	GHP-4-2	ホール	SA	1,440	E2	#25	480	3	450 × 450 × 400														
	GHP-4-2	ELVホール	SA	480	BL-D	2,400L	480	1	300 × 2600 × 400														無結露タイプ
	GHP-4-1、GHP-4-2	設備スペース1										RA	5,870	HS	450 × 1300	2,935	2	500 × 500 × 1500				設計外気量 1,810m3	
	GHP-4-1、GHP-4-2	設備スペース1	RA ⁿ ス	5,870	金網	1250 × 650	5,870					RA ⁿ ス	4,860	HS	850 × 850	4,860	1	1100 × 1100 × 400				(企業人材支援課・ホール)	
												RA ⁿ ス	1,020	HS	550 × 550	1,020	1	700 × 700 × 200				(ホール)	
												EA ⁿ ス	180	HS	250 × 250	200	1	400 × 400 × 350				(ホール)	
	HEX-2-1	打合せ室	SA	180	VHS	250 × 200	250	1	400 × 400 × 350														
	ホール	ホール	EA ⁿ ス	180	VHS	250 × 250	200	1	400 × 400 × 350													(打合せ室)	
	HEX-2-1	設備スペース1	OA	1,810		(RAチャンバー)	905	2				EA	1,										